



Checklist for Electrical Safety

	Yes	No	Action Required
Are all plugs, sockets and electrical fittings sufficiently robust for use in the factory?			
Are all electrical fuse/junction boxes in the factory securely fixed, closed and undamaged?			
Are fuses, circuit breakers and other electrical devices correctly rated for the circuit they protect?			
Is access to fuse boxes prevented and the key held by a responsible person?			
Are main switches readily accessible and clearly identified, with all workers knowing how to use them in an emergency?			
Are all electrical installations checked periodically and repairs carried out by a competent electrician?			
Are there any cables or wires without proper casing, found in the factory?			
Are any electrical wires improperly spliced or taped?			
Is electrical equipment properly grounded to prevent electrocution or fire?			
Are any electrical wires found in damp areas or standing water?			
Are any electrical wires obstructing aisles or passageways?			
Are all visible electrical wires securely fixed?			



Electrical fittings and installations must be checked on a regular basis.